

## ATTACHMENT E

### **Customer Checklist for Utility Interconnection**

- Submit an application to Okanogan PUD with \$100.00 application fee:
  - ✓ Interconnection inverter must be UL 1741 listed.
  - ✓ An electrical schematic drawing must be included.
  - ✓ Submit cut sheets for products used in the generating system.
  - ✓ Okanogan PUD does not provide or require a production meter.
  - ✓ All customer meters are already bi-directional.
  - ✓ Include provisions for a lockable visible disconnect if required by the PUD or local jurisdiction.
  
- Send application, schematic, and cut sheets to:
  - Okanogan County PUD
  - PO Box 912
  - Okanogan, WA 98840
  - Attn: Kim Johnson
  
- Receive written design approval from Okanogan PUD.
- Get an electrical permit from Washington State L&I. Follow the National Electric Code (NEC) as required.
- If production metered, applicant purchases and installs production meter.
- Complete the installation.
- Get inspection from a state electrical inspector. When approved, call the PUD for their inspection.
- Submit Attachment B: Certificate of Completion to the Utility (on website).
- Start generating power.

For questions, please contact Kim Johnson at 509-422-8428.